

# AMENDMENT NO. 4 MARCH 2020

## TO


### IS 694 : 2010 POLYVINYL CHLORIDE INSULATED UNSHEATHED AND SHEATHED CABLES/CORDS WITH RIGID AND FLEXIBLE CONDUCTOR FOR RATED VOLTAGES UP TO AND INCLUDING 1 100 V

(Fourth Revision)

[Page 3, clause 8.1 b), line 1] — Substitute ‘insulated’ for ‘sheathed’.

[Page 4, clause 10.1, line 2] — Substitute ‘minimum’ for ‘approximately’.

[Page 6, Fig. 1 (see also Amendment No. 3)] — Substitute the following ‘Fig. 1’ for the existing:



$d$  is distance between prints which shall be maximum 50 mm.

FIG. 1 PREFERRED ARRANGEMENT OF MARKING  
(EXAMPLE FOR ARRANGEMENT OF MARKING FOR CORE NO. 12)

[Page 10, Table 3, Sl No. iv), col 4 (see also Amendment No. 3)] — Substitute ‘0.6’ for ‘0.7’.

(Page 11, clause 18.1.4, line 2) — Substitute ‘ST2’ for ‘ST2 (HR)’.